

Sto Canada Master Specification StoQuik® Gold Finish System for Soffits and Ceilings June 2017_001 No. CA-1400 Acrylic Plaster Finish Section 09 25 13.13 Page 1 of 5

SPEC NOTE: IMPORTANT: This guide specification covers installation of a textured finish system over building code compliant soffit or ceiling construction. It does not address air sealing, soffit or ceiling ventilation, construction detailing, flashing, drip edges, and other important aspects of design and construction that must be taken into consideration to prevent water infiltration, to prevent condensation caused by air leakage or water vapour diffusion, and to comply with applicable fire safety requirements. Consult with a qualified design professional for overall design of the soffit/ceiling assembly.

SPEC NOTE: Notes in italics, such as this one, are explanatory and intended to guide the design/construction professional and user in the proper selection and use of materials. This specification should be modified where necessary to accommodate individual project conditions.

PART 1 GENERAL

1.1 SUMMARY

.1 Provide textured finish system for gypsum or cement board soffit and ceiling surfaces.

1.2 SUBMITTALS

.1 Product Data: Submit manufacturer's product data and installation instructions for each material and product used. Include manufacturer's Safety Data Sheets.

1.3 REFERENCES

- .1 American Society for Testing and Materials (ASTM)
 - .1 ASTM C1177, Specification for Glass Mat Gypsum for Use as Sheathing
 - .2 ASTM C1325, Specification for Non-Asbestos Fiber-Mat Reinforced Cementitious Backer Units

1.4 QUALITY ASSURANCE

- .1 Manufacturer's Qualifications: The textured finish system manufacturer shall be a company with at least thirty five years of experience in manufacturing specialty finishes and regularly engaged in the manufacture and marketing of products specified herein. The manufacturer shall have an ISO 9001:2008 certified quality system and ISO 14001:2004 certified environmental management system.
- .2 Installer's Qualifications: The contractor shall be qualified to perform the work specified by reason of experience. Contractor shall have at least 5 years of experience in commercial textured finish application, and shall have completed at least 3 projects of similar size and complexity. Contractor shall provide proof before commencement of work that he/she will maintain and supervise a qualified crew of applicators through the duration of the work. When requested Contractor shall provide a list of the last three comparable jobs including the name, location, and start and finish dates for the work.



Acrylic Plaster Finish Section 09 25 13.13 Page 2 of 5

- .3 Mock-ups: The contractor shall install a mock-up of the system for evaluation and approval by the design professional, building owner, or owner's representative/quality assurance agent.
- .4 Testing: Testing shall be conducted as directed by the design professional, building owner, or owner's representative/quality assurance agent to verify soffit/ceiling assembly performance and adhesion to prepared substrates.

1.5 DELIVERY, STORAGE AND HANDLING

- .1 Deliver products in original packaging, labeled with product identification, manufacturer, and batch number.
- .2 Store products in a dry area with temperature maintained between 10 and 29 degrees C (50 and 80 degrees F). Protect from direct sunlight. Protect from freezing. Protect from extreme heat (> 32 degrees C [90 degrees F]).
- .3 Handle products in accordance with manufacturer's printed instructions.

1.6 WARRANTY

.1 Provide manufacturer's standard limited warranty.

PART 2 PRODUCTS

2.1 MATERIALS

SPEC NOTE: Select one of the following textured finish options, and delete the finish not required on the project.

- .1 Textured Finishes
 - .1 Stolit high performance decorative and protective acrylic-based textured wall finish with integral colour
 - .2 Sto Essence DPR high performance decorative and protective textured wall finish with integral colour.

SPEC NOTE: The primer is an optional component. Priming is recommended to provide uniform substrate absorption and finish colour, to improve adhesion and water resistance, and to retard efflorescence. Delete this section if a primer will not be used.

- .2 Primer
 - .1 StoPrime[™] Sand acrylic-based sanded primer
 - .2 StoPrime[™] acrylic-based smooth primer

SPEC NOTE: Select one of the following base coat options, and delete the base coats not required on the project.

.3 Base Coat



Sto Canada Master Specification StoQuik® Gold Finish System for Soffits and Ceilings June 2017_001 No. CA-1400

Acrylic Plaster Finish Section 09 25 13.13 Page 3 of 5

- .1 Sto BTS Xtra one component polymer modified portland cement-based extra high build base coat
- .2 Sto BTS Plus one component polymer modified portland cement-based high build base coat
- .3 Sto Primer/Adhesive-B one component polymer modified portland cement-based base coat
- .4 Surface Reinforcement
 - .1 Sto Mesh nominal 153 g/m² (4.5 oz/yd²) glass fibre reinforcing mesh treated for compatibility with Sto materials
 - .2 Sto Detail Mesh nominal 142 g/m² (4.2 oz/yd²) glass fibre reinforcing mesh treated for compatibility with Sto materials
 - .3 StoGuard Mesh nominal 142 g/m² (4.2 oz/yd²) self-adhesive glass fibre reinforcing mesh treated for compatibility with Sto materials
- .5 Gypsum or Cement Soffit Board
 - .1 Glass mat faced gypsum sheathing in compliance with ASTM C1177
 - .2 PermaBase[®] Brand cement board in compliance with ASTM C1325

PART 3 EXECUTION

3.1 INSTALLATION

SPEC NOTE: SPEC NOTE: Coarse texture finishes (equal to or greater than 1.5 mm texturing aggregate) are recommended to hide trowel marks and other minor surface imperfections in the base coat surface. Fine or smooth texture finishes require tighter tolerances than coarse textures. Where fine or smooth texture finishes are used a second application of base coat and/or a skim coat of Stolit Milano may be necessary to provide a smooth enough surface for an acceptable finished soffit or ceiling surface. The approved mock up shall be the basis for acceptable tolerances, finished appearance, and the number of layers of base coat or skim coat needed to achieve the finished appearance, as determined by the design professional, owner, or owner's representative/quality assurance agent.

- .1 Gypsum or cement soffit board must be installed in conformance with the applicable building code and manufacturer's written installation instructions. Gypsum or cement soffit board surface must be clean, dry, and free of surface contamination. Soffit board surface shall not have planar irregularities in excess of 1.6 mm (1/16 inch) at joints, and not more than 3 mm in 3 m (1/8 inch in 10 feet), and shall be free of voids, cracks, and other surface defects.
- .2 Mixing
 - .1 Mix Sto products in accordance with published literature. Refer to applicable Product Bulletins for specific information on use, handling, application, precautions, and limitations of specific products.
- .3 Application



Acrylic Plaster Finish Section 09 25 13.13 Page 4 of 5

Sto Canada Master Specification StoQuik® Gold Finish System for Soffits and Ceilings June 2017_001 No. CA-1400

- .1 Install corrosion proof termination accessories with perforated flanges for keying of the base coat at junctures with penetrations such as soffit vents, electrical fixtures, and with abutting walls and columns. Install corrosion proof control joints with perforated flanges for keying of the base coat at intervals as required by the soffit board manufacturer. Refer to Sto Guide details.
- .2 Reinforce perforated flanges of accessories with minimum 100 mm (4 inch) wide strips of Sto Detail Mesh or Sto Mesh embedded in base coat. Where cement board is used tape joints between cement board s with minimum 100 mm (4 inch) wide StoGuard Mesh and skim with base coat. Alternatively tape joints with minimum 100 mm (4 inch) wide Sto Mesh or Sto Detail Mesh embedded n base coat. Allow base coat to dry.
- .3 Install nominal 3 mm (1/8 inch) base coat by trowel to the soffit/ceiling board surface. Work horizontally or vertically in strips of 1000 mm (40 inches), and immediately embed the mesh into the wet base coat by troweling from the center to the edge of the mesh. Overlap mesh installed at perforated accessory flanges by installing Sto Mesh up to the termination bead of the accessory. Overlap mesh not less than 65 mm (2-1/2 inches) at mesh seams and feather at seams. Double wrap all inside and outside corners with minimum 200 mm (8 inches) overlap in each direction. Where corner bead is used at outside corners lap mesh over perforated flange of accessory. Avoid wrinkles in the mesh. The mesh must be fully embedded so that no mesh colour shows through the base coat when it is dry. Re-skim with additional base coat if mesh colour is visible. Do not install base coat and mesh onto solid (unperforated) portions of accessories.

SPEC NOTE: Delete step 3 if the optional primer is not used.

- .4 When the base coat application is dry apply the primer by brush or roller to the entire base coat surface.
- .5 When the primer application is dry apply the textured finish by trowel. Apply finish in a continuous application, and work to a wet edge. Float the finish to achieve the desired texture.
- .4 Protection
 - .1 Provide protection of installed materials from water infiltration into or behind them during and after construction.
 - .2 Provide protection of installed materials from dust, dirt, precipitation, freezing and continuous high humidity until they are fully dry.
 - .3 Seal penetrations through the finished surface with backer rod and sealant or other appropriate means.

END OF SECTION 09 25 13.13

ATTENTION

Sto products are intended for use by qualified professional contractors, not consumers, as a component of a larger construction assembly as specified by a qualified design professional, general contractor or builder. They should be installed in accordance with those specifications and Sto's instructions. Sto Corp. disclaims all, and assumes no, liability for on-site inspections, for its products



Acrylic Plaster Finish Section 09 25 13.13 Page 5 of 5

Sto Canada Master Specification StoQuik® Gold Finish System for Soffits and Ceilings

June 2017_001 No. CA-1400

applied improperly, or by unqualified persons or entities, or as part of an improperly designed or constructed building, for the nonperformance of adjacent building components or assemblies, or for other construction activities beyond Sto's control. Improper use of Sto products or use as part of an improperly designed or constructed larger assembly or building may result in serious damage to Sto products, and to the structure of the building or its components. <u>STO CORP. DISCLAIMS ALL WARRANTIES</u> <u>EXPRESS OR IMPLIED EXCEPT FOR EXPLICIT LIMITED WRITTEN WARRANTIES ISSUED TO AND ACCEPTED BY</u> <u>BUILDING OWNERS IN ACCORDANCE WITH STO'S WARRANTY PROGRAMS WHICH ARE SUBJECT TO CHANGE FROM</u> <u>TIME TO TIME</u>. For the fullest, most current information on proper application, clean-up, mixing and other specifications and warranties, cautions and disclaimers, please refer to the Sto Corp. website, <u>www.stocorp.com</u>.